



MPA | Eberswalde

TEST CERTIFICATE

No. 31/21/4350/01 TC

CERTIFICATE HOLDER:

KNAUF GYPSOPIIA A.B.E.E.
Euripidou Str. 10
17674 Kalithea, Athens
Greece


The product **GKB - standard gypsum board 12,5 mm** (manufacturing plant: Gypsum Products Factory, 30500 Stanos, Amfilochia, Greece) was tested as product for walls (loading factor: 1,0 m²/m³) according to EN 16516 "Construction products: Assessment of release of dangerous substances – Determination of emissions into indoor air" and assessed according to evaluation procedures for VOC emissions from building products.

GKB – standard gypsum board 12,5 mm


complies with the following requirements for VOC emissions:

Belgian VOC regulation	✓
French VOC class A+	✓
German AgBB (2021) / ABG	✓
Finnish M1	✓
EMICODE EC1 ^{Plus}	✓
LEED v4.1 (low emitting materials; projects outside of the U.S.)*	✓

MPA Eberswalde
Materialprüfanstalt Brandenburg GmbH
28.06.2021


Dr. Peter Schumacher
Head of Institute




Dr. Robby Wegner
Head of Chemical Testing

Details of testing: MPA test report 31/21/4350/01 of 28.06.2021: VOC emission chamber test (EN 16516)

* The product meets the requirements as VOC emissions comply with Finnish M1 and EMICODE EC1^{Plus}.

MPA Eberswalde is accredited under ISO/IEC 17025 for testing according to:
CEN/TS 16516:2014, DIN EN 16516:2015, EN 16516:2017 and EN 16516:2017+A1:2020.