

PENETRATION & LINEAR GAP SEALS SCHEME SDP 14

Certificate number: IFCC 1940

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Knauf Insulation Ltd

Stafford Road

St Helens

Merseyside

WA10 3LZ

Tel: 01744766600

Which manufacture the following systems:

Rocksilk® RainScreen FireStop Slab

At manufacturing sites: **A-K4 & A-K5**, have satisfied the requirements of the Penetration & Linear Gaps SDP 14 scheme v1.6. This includes the testing of products to **EN1366-4: 2021**, the inspection of their Factory Production Control, and continuing surveillance audits and testing of samples of products taken from production. The product specification and reports are detailed on page 2 of this certificate.

Initial Certification: 21 June 2024

Revised: 23 June 2025

Valid to: 20 June 2029

Issue number: 2


David Mowatt

Head of IFC Certification /

Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



**Rocksilk® RainScreen FireStop Slab**

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
Up to 300mm	M	180/45	5	100	Horizontal Vertical	WF 358532 (C) WF 513883 (E)
Up to 450mm	CP1	120/45	5	100	Horizontal Vertical	WF 502321A (A) WF 510928 (D)

M = Masonry, CP1 = CP board 1 side &/or masonry

Rocksilk® RainScreen FireStop Slab – PAR/25277/02

Product	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Cavity width (mm)	Orientation	Cavity Insulation
RRFS450	C, M, S	120/120	2	100-450	Horizontal	Rainscreen Slab / EE
RRFS450	C, M, S	120/120	2	100-450	Vertical	Rainscreen Slab / EE
RRFS100	C, M, S	120/120	2	60-100	Horizontal	Rainscreen Slab
RRFS100	T-W	120/120	2	60-100	Vertical	Rainscreen Slab
RRFS300 with masonry support	C, M	120/90	2	100-300	Horizontal	Rainscreen Slab / EE
RRFS100 with masonry support	C, M	120/120	2	60-100	Horizontal	Rainscreen Slab

M = Masonry, C = Concrete, S = Sheathing board, T-W = Timber framework with Windliner board.

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.