



PENETRATION & LINEAR GAP SEALS SCHEME SDP 14

Certificate number: IFCC 2054

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Knauf Insulation Ltd

Stafford Road
St Helens
Merseyside
WA10 3LZ
Tel: 01744766600

Which manufacture the following systems:

Rocksilk® RainScreen FFCB

At manufacturing sites: **A-K4 & A-K5**, have satisfied the requirements of the Penetration & Linear Gaps SDP 14 scheme v1.6. This includes the testing of products to **BS EN1366-4: 2021**, the inspection of their Factory Production Control, and continuing surveillance audits and testing of samples of products taken from production. The product specification and reports to achieve **up to 120 minutes integrity and insulation** are detailed on page 2 of this certificate.

Initial Certification: 13 October 2025

Valid to: 20 June 2030

Issue number: 1

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*

CERTIFICATE





The scope of approval is in accordance with the assessment / test reports referenced within the following table:

Rocksilk® RainScreen FFCB – PAR/25278/01

Product	FFCB thickness (mm)	Rating Integrity (E) (mins)	Rating Insulation (I) (mins)	Compression Fit (mm)	Orientation
Rocksilk® RainScreen FFCB	100	90	30 *1	2	Horizontal
Rocksilk® RainScreen FFCB	150	120	90	2	
Rocksilk® RainScreen FFCB	100	60	15	2	Horizontal over Masonry Support Brackets
Rocksilk® RainScreen FFCB	150	45	30	2	
Rocksilk® RainScreen FFCB	100	60 *2	30 *1	2	Vertical
Rocksilk® RainScreen FFCB	150	120	90	2	
Rocksilk® RainScreen FFCB	200	120	90 *3	2	

Notes:

*1 – Where cavity insulation is up to 50mm thick, and the total cavity depth (including cavity insulation) does not exceed 100mm, 60 minutes insulation performance is approved

*2 – Where cavity insulation is up to 50mm thick, and the total cavity depth (including cavity insulation) does not exceed 100mm, 90 minutes integrity performance is approved

*3 – Where cavity insulation is up to 100mm thick, and the total cavity depth (including cavity insulation) does not exceed 210mm, 120 minutes insulation performance is approved

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.



CERTIFICATE