

Emission Test Certificate

Tuesday 10th May 2022

Supplier: Knauf Gypsum Pty Ltd (3 Thackeray Street, Camellia, NSW, 2142, Australia)

Sample Description: Sheetrock Plasterboard

Date Tested: May 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 Hours):

<p>Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>Sheetrock Plasterboard</p>
<p>Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.005 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: <0.004 mg/m²/hr</p>
<p>We hereby certify that VOC and Formaldehyde emission rate from this product is below the limits specified by Green Building Council of Australia, Green Star Interiors requirements.</p>	
<p>The above results may be considered representative of Sheetrock ONE, Sheetrock HD, Flexiboard, Wetstop, Sheetrock Unispan, Echostop, Knauf Sheetrock Cove Cornice range, and Knauf Decorative Cornice range manufactured and supplied by Knauf Gypsum Pty Ltd.</p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issue date: 30/5/2022

Expiry date: 30/5/2027

P22040014_Ver1