

VOC Content Test Certificate

Monday 14th August 2023

Supplier: Knauf Gypsum Pty Ltd (3 Thackeray Street, Camellia, NSW 2142, AUSTRALIA).

Product Name: Knauf All Purpose Premix

Date Tested: 14th August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Knauf All Purpose Premix
General Purpose Adhesives and Sealants: 50 grams per litre	6 grams per litre as VOC content per material
<i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by Knauf Gypsum Pty Ltd and these include FinalCote, LiteFinish, Total Lite, RediBase, and All Purpose Premix and Total Joint Finish.</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant