

NOTE:  
KNAUF FIRESTOP®LININGS CAN BE  
INSTALLED HORIZONTALLY OR  
VERTICALLY, OR WITH MIXED  
ORIENTATION TO KNAUF SPECIFICATIONS

RONDO DEFLECTION HEAD J-TRACK FIXED  
TO CONCRETE SOFFIT WITH APPROVED  
FASTENERS @ 600mm CTRS MAX AND  
100mm MAX FROM ENDS

25mm KNAUF SHAFTLINER™MOULDSTOP PANEL

KNAUF FIRESTOP®AS SPECIFIED FOR SHAFTWALL  
SYSTEM. STAGGER JOINS WITH OPPOSITE LAYERS  
BY 300mm MIN VERTICALLY AND HORIZONTALLY.

WHERE SHAFTWALL EXCEEDS MAXIMUM AVAILABLE  
PANEL HEIGHT, POSITION SHAFTLINER™MOULDSTOP  
END JOINS WITHIN UPPER AND LOWER THIRDS OF  
WALL. ALTERNATE THE JOINTS TOP AND BOTTOM  
WITH THE ADJACENT PANELS AND REINFORCE END  
JOINTS WITH HORIZONTAL RONDO CH-STUDS.

RONDO CH-STUDS @ 600mm CTRS MAX

KNAUF INSULATION AS REQUIRED

RONDO J-TRACK FIXED TO CONCRETE SLAB  
WITH APPROVED FASTENERS @ 600mm CTRS  
MAX AND 100mm MAX FROM ENDS

20mm MAX GAP CONTINUOUSLY FILLED WITH  
FIRESOUND®SEALANT AT HEAD OF SHAFTWALL

KNAUF FIRESTOP®AS SPECIFIED FOR SHAFTWALL SYSTEM.  
STAGGER JOINS WITH OPPOSITE LAYERS BY 300mm MIN  
VERTICALLY AND HORIZONTALLY.

KNAUF FIRESTOP®FIXED WITH TYPE "S" OR "D"  
SCREWS @ 300mm CTRS MAX ON STUDS

TAPE AND SET JOINTS WITH PAPER TAPE

STOP EXPOSED FASTENERS ON FACE LAYER

KNAUF FIRESTOP®FIXED WITH TYPE "S" OR  
"D" SCREWS @ 200mm CTRS MAX AT SHEET ENDS AND  
CORNERS. SCREWS STAGGERED IN ABUTTING SHEETS

SCREW FIXINGS 10mm-16mm FROM EDGE OF SHEET

6-10mm GAP CONTINUOUSLY FILLED WITH FIRESOUND®  
SEALANT AT BASE OF SHAFTWALL

SHAFTWALL INSTALLATION OVERVIEW  
SCALE NTS FRL AS PER TABLE  
[FC12549]

LINING SIDE 1	LINING SIDE 2	FRL
1x16FS + 1x25SL	1x16FS	-/120/120
SL=SHAFTLINER™MOULDSTOP FS=FIRESTOP®		

Notes:

- Recommendation and proposed systems are subjected to the project engineer and building surveyor/certifier's approval. If approved, a copy of the construction drawing should be sent to Knauf for review.
- All details provided in this document are to be read in conjunction with the relevant Knauf brochures. All installation and construction details are to be in accordance with Knauf's specification.
- All acoustic ratings provided are ±2dB for Rw, and ±3dB for Rw+Ctr.
- Any lining designated as FIRESTOP can be replaced by IMPACTSTOP or MULTISTOP ONE or ONE HI of equal or greater thickness without adversely affecting fire resistance level or acoustic rating. Replacing IMPACTSTOP or MULTISTOP ONE or ONE HI with FIRESTOP may reduce acoustic performance, refer Knauf for information.
- Any lining designated as 10mm SHEETROCK ONE can be replaced by 10mm SHEETROCK PLUS without adversely affecting acoustic rating. Replacing 10mm SHEETROCK PLUS with 10mm SHEETROCK ONE may reduce acoustic performance, refer Knauf for information.
- Any lining designated as 13mm SHEETROCK ONE can be replaced by 13mm WETSTOP without adversely affecting acoustic rating. Replacing 13mm WETSTOP with 13mm SHEETROCK ONE may reduce acoustic performance, refer Knauf for information.

2	MARKET UPDATE	TH	01/10/25
1	APPROVED FOR ISSUE	DA	15/09/22
REV:	DESCRIPTION:	BY:	DATE:

AMENDMENTS:

**KNAUF**

TECHNICAL CENTRE

17/47 Turner St  
Port Melbourne Vic 3207 AUSTRALIA  
TecAssist: 1800 811 222  
W: www.knauf.com E: TecAssist@knauf.com

SHAFTWALL INSTALLATION

TITLE: OVERVIEW

GS	2	01/10/25
DRAWN.	REVISION.	DATE.

SHW-002A

DRAWING NO.